

Government of Andhra Pradesh

A.P. State Disaster Response and Fire Services Department

Periodical Renewal Fire Certificate

From:
District Disaster Response & Fire Officer
Andhra Pradesh, Eluru

To:
The Management of Ekalavya Model
Residential School Campus,,
Principle, EMRS Buttayagudem, Eluru
District.

File No: 28094/ELR/DFO/2025, Date:25/09/2025
Occupancy NoC RC Number: 22056/ELR/MSB/2024

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of Eklavya Model Residential School, Vippalapadu, buttayagudem, 534448, represented by Principal, EMRS, Eklavya Model Residential School, Vippalapadu, buttayagudem, 534448 - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
 3. This Office NOC for Occupancy Rc No. 22056/ELR/MSB/2024, Dt.09/08/2024
 4. Renewal NOC For Occupancy 22056/ELR/MSB/2024, Dt.09/08/2025
 5. Online Application for Renewal NOC of Principal, EMRS, Eklavya Model Residential School, Vippalapadu, buttayagudem, 534448 - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 19-09-2025.

-- x --

The Management of Eklavya Model Residential School, Vippalapadu, buttayagudem, 534448, represented by Principal, EMRS, Eklavya Model Residential School, Vippalapadu, buttayagudem, 534448 has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.49850/- vide challan No. 90106399042025, Dated 19/09/2025 at ONLINE, ONLINE.

Educational ,Principal Quarters ,Type III Block A Quarters ,Type III Block B Quarters ,Boys Warden Quarters ,Kitchen and Dining ,Boys Dormitory ,Girls Warden Quarters ,Type II(Qtr No:01-10) ,Girls Dormitory

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **Principal, EMRS Eklavya Model Residential School, Vippalapadu, buttayagudem, 534448**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.

2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 25/09/2025 to 24/09/2026.
5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

Challan Number	Challan Date	Challan Amount
90106399042025	19/09/2025	49850

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

1. This Renewal NOC is issued from Fire Safety Point of view only basing on recommendation of the Inspection Committee and this Renewal NOC is not for claiming proprietary or ownership rights.
2. Further, In case of any deviation noticed with respect to this Renewal NOC after issuance of his Renewal NOC, the same Renewal NOC shall be liable for cancellation at any time.
3. the Occupier/Owner/ Builder/Management, concerned of the building premises, shall maintain the fire Prevention and Fire Safety Measures provided by the building as per Table -7, Part -IV, NBC -2016 at all times for good use by the occupant (or) Members of Fire Services (or) Both in the event of outbreak of Fire.

Your Sincerely,

[Signature]
25/9/2025

District Disaster Response & Fire Officer Andhra Pradesh, Eluru

Copy to Management Principal, EMRS, Eklavya Model Residential School, Vippalapadu, near ITI

College, Buttayagudem, 534448

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned